

WELL COMPLETION REPORT

1. Permit Number: 36593
 Owner of Well: Edward Letterson

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 58 feet
 Date Completed 7-10-76

4. Grout: Type Cement
 from 3 feet to 15 feet
 from _____ feet to _____ feet

5. Casing: Type PVC
0 inches to 53 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
53 feet to 58 feet

7. Gravel Packed? Yes No
51 feet to 58 feet

13. Well Log

8. Well Head Completion:
10 Pitless Adapter _____ Type
 _____ inches above grade

9. Static Water Level:
9 feet below grade
 _____ feet above grade

10. Pumping Water Level:
20 feet below grade after
1 hour at 25 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

PC52-06

Formation	Thickness of Stratum	Depth to Bottom of Stratum
yellow sand	0	3
brown sand med	3	8
to brown sandy clay	8	16
to brown sand med	16	25
brown sand med	25	30
brown clay	30	33
brown sand med	33	50
brown sand med coarse	50	58