

PA 23 06

Permit Number: 38771  
Owner of Well: Richard Brezner

Test Well \_\_\_\_\_  
Observation Well \_\_\_\_\_  
Production Well   
Well Abandoned? Yes \_\_\_\_\_ No

Total Well Depth 47 feet  
Date Completed July 6 1977

Grout: Type none  
from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Casing: Type PVC plastic  
2 inches to 37 feet  
\_\_\_\_\_ inches to \_\_\_\_\_ feet  
Drive Shoe? Yes \_\_\_\_\_ No

Screen Setting:  
37 feet to 47 feet

Gravel Packed? Yes  No \_\_\_\_\_  
37 feet to 47 feet

8. Well Head Completion:  
Pitless Adapter \_\_\_\_\_ Type \_\_\_\_\_  
8 inches above grade

9. Static Water Level:  
10 feet below grade  
\_\_\_\_\_ feet above grade

10. Pumping Water Level:  
20 feet below grade after  
1/2 hours at 25 GPM

11. Permanent Pump Installed?  
Yes \_\_\_\_\_ No   
a. Shallow Well \_\_\_\_\_  
   Deep Well \_\_\_\_\_  
b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
   Centrifugal \_\_\_\_\_ Jet \_\_\_\_\_  
   Submersible \_\_\_\_\_  
c. Capacity \_\_\_\_\_ GPM

12. Well Number \_\_\_\_\_  
(Leave Blank)

Formation:	Thickness of Stratum	Depth to Bottom of Stratum
<u>white sand</u>	<u>5</u>	<u>5</u>
<u>yellow sand and clay</u>	<u>5</u>	<u>10</u>
<u>white sand gravel</u>	<u>10</u>	<u>20</u>
<u>fine sand</u>	<u>20</u>	<u>40</u>
<u>coarse sand gravel</u>	<u>7</u>	<u>47</u>

Nature of Water Well Contractor  
Ernest L. Smith

Date  
July 6 1976