

**A-701**  
 WATER SUPPLY BRANCH  
 DIVISION OF ENVIRONMENTAL CONTROL  
 P.O. BOX 1401  
 DOVER, DELAWARE 19903

**STATE OF DELAWARE  
 DEPARTMENT OF NATURAL RESOURCES  
 AND ENVIRONMENTAL CONTROL**

WELL COMPLETION REPORT MUST  
 BE RETURNED 30 DAYS AFTER  
 CONSTRUCTION DATE

**WELL COMPLETION REPORT**

PLEASE PRINT

PERMIT NO. 74674 LOCAL ID 101

OWNER Melvin Joseph  
Rte. #1, Box 218, Greer, S.C.

CONSTRUCTION DATE 6-23-88  
 PURPOSE  TEST  PERMANENT

- USE  DOMESTIC  AGRICULTURAL  
 COMMERCIAL  INDUSTRIAL  
 IRRIGATION  PUBLIC  
 MONITOR  DEWATERING  
 HEAT PUMP RECHARGE  HEAT PUMP SUPPLY  
 OTHER (Specify) \_\_\_\_\_

IS THIS A REPLACEMENT WELL? YES  NO   
 ABANDONMENT DATE FOR OLD WELL \_\_\_\_\_  
 ABANDONMENT METHOD \_\_\_\_\_

- DRILLING METHOD  
 AUGERED  BORED  CABLE TOOL  
 DRIVEN  JETTED  AIR ROTARY  
 MUD ROTARY  REVERSE  WASHED  
 OTHER (Specify) \_\_\_\_\_  
 TOTAL DEPTH DRILLED 81

**CASING SEQUENCE**

	FEET	GRADE
CASING TOP	+1	
CASING BOTTOM	21	
CASING DIAMETER	8	
CASING MATERIAL	PVC	

**SCREEN SEQUENCE**


	FEET	GRADE
SCREEN TOP	21	
SCREEN BOTTOM	81	
SCREEN DIAMETER	8	
SCREEN MATERIAL	PVC	

WRITER APPROVAL FOR SCREENING/  
 GRAVEL PACKING SHALL BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT  BENTONITE CLAY   
 OTHER: \_\_\_\_\_  
 FROM 3 TO 20 FEET  
 NON-GROUT BACKFILL OF WELL ANNULUS  
 TYPE SAND/CLAY FROM 20 TO 81 FEET  
 GRAVEL PACK: TYPE GRIT  
 FROM 20 TO 81 FEET  
 STATIC WATER LEVEL: DATE 6-23-88  
8 FT. (below) ABOVE GROUND SURFACE  
 PUMPING WATER LEVEL: 40 FT. BELOW GRADE  
 AFTER 5 HOURS AT 100 GPM

**WELL HEAD COMPLETION:**  
 TYPE: PITLESS ADAPTOR   
 OTHER   
12 INCHES ABOVE GRADE.

**TYPE OF PERMANENT PUMP INSTALLED:**  
 PUMP MANUFACTURE \_\_\_\_\_  
 RATED CAPACITY (GPM) 7  
 PUMP INTAKE SETTING \_\_\_\_\_ FT. BELOW GRADE  
**THE COMPLETED WELL IS?**  
 YES NO  
 A. AT LEAST 15' FROM ANY FOUNDATION    
 B. AT LEAST 50' FROM ANY SEPTIC TANK    
 C. AT LEAST 10' FROM TOWN SEWER LINE    
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD    
**THE NEAREST NEIGHBORS (CIRCLE ONE)**  
 SEPTIC  TILE FIELD  CESSPOOL OR PRIVY   
 IS \_\_\_\_\_ FROM COMPLETED WELL.  
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?    
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS



**DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA**

	0	1
Topsoli		
Fine White Sand	1	8
Tan Sand	8	20
Creo Tan Sand	20	45
Med./Creo Dark Tan Sand	45	60
Creo Tan Sand	60	81

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO   
 PAGE 1 OF 1 PAGES  
 COMPANY NAME LIFETIME WELL DRILLING CO.  
 SIGNATURE OF DRILLER IN CHARGE W. M. E. Wood DATE \_\_\_\_\_

Document 20-06/76/05/10