

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69
 WATER SUPPLY BRN

WELL COMPLETION REPORT

DEC 3 1976

1. Permit Number: 37412
 Owner of Well: Bonnie T. Phillips

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 65 feet
 Date Completed 11-23-76

4. Grout: Type none
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC
0 inches to 65 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting: 60 feet to 65 feet

7. Gravel Packed? Yes No
60 feet to 65 feet

8. Well Head Completion:
No Pitless Adapter Type
8 inches above grade

9. Static Water Level:
12 feet below grade
 feet above grade

10. Pumping Water Level:
16 feet below grade after
2 hours at 60 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

13. Well Log

PF25-17

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Fine brown sand	10'	10'
Coarse " "	5'	15'
Medium " "	5'	20'
Coarse " "	25'	45'
" yellow " w/gravel	10'	55'
" brown "	10'	65'