

1. Permit Number: 36723
 Owner of Well: George Essert

3. Well Head Completion:
No Pickless Adapter _____ Type
8 inches above grade

2. Test Well
 Observation Well _____
 Production Well _____
 Well Abandoned? Yes _____ No

9. Static Water Level:
10 feet below grade
 _____ feet above grade

3. Total Well Depth 76 feet
 Date Completed 8-7-76

10. Pumping Water Level:
17 feet below grade after
2 hours at 50 GPM

4. Crout: Type None
 from _____ feet to _____ feet
 from _____ feet to _____ feet

11. Permanent Pump Installed?
 Yes _____ No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

5. Casing: Type 2" PVC
0 inches to 76 feet
 _____ inches to _____ feet
 Drive Shoe? Yes _____ No

6. Screen Setting:
21 feet to 76 feet

7. Gravel Packed? Yes _____ No
21 feet to 76 feet

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Medium fine brown sand	10'	10'
Medium white sand	15'	25'
" brown yellow "	30'	55'
" fine yellow "	10'	65'
" coarse red dark brown "	11'	76'

14. Signature of Water Well Contractor Burns

Date August 8, 1976