


PERMIT MUST BE RETURNED TO THE STATE DEPARTMENT OF NATURAL RESOURCES AND ENVIRONMENTAL CONTROL PERMIT RECEIVED BEFORE WORK IS STARTED



IN RELATION TO ROADS AND OTHER FEATURES

Handwritten notes and signatures in the left margin.

PERMIT NO. 60736

BE ONLY FORMATION

CONSTRUCT AND USE A WELL AS SOURCE USE MUST BE FOLLOWED.

Company
60736
6/20/85
TWENTY ONE (21) DAYS AFTER

MAIL TO:
WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1401
DOVER DELAWARE 19901

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST BE RETURNED 21 DAYS AFTER CONSTRUCTION DATE

WELL COMPLETION REPORT

PERMIT NO. 60736 LOCAL ID 14

OWNER Shelley, Nancy

CONSTRUCTION DATE 5/21/85
PURPOSE TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify)

IS THIS A REPLACEMENT WELL? YES NO
ABANDONMENT DATE FOR OLD WELL By owner
ABANDONMENT METHOD

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN BITED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify)
TOTAL DEPTH DRILLED 75'

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	<u>2.2'</u>			
CASING BOTTOM	<u>-1.5'</u>			
CASING DIAMETER	<u>2"</u>			
CASING MATERIAL	<u>PVC</u>			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	<u>-0.5'</u>			
SCREEN BOTTOM	<u>-75'</u>			
SCREEN DIAMETER	<u>2"</u>			
SCREEN MATERIAL	<u>PVC</u>			

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE SQUARE MUST BE OBTAINED FROM OWNER.

GROUT TYPE: CEMENT BENTONITE CLAY
OTHER:
FROM 0 TO 20 FEET
NON-GROUT BACKFILL OF WELL ANNULUS
TYPE FROM TO FEET
GRAVEL PACK TYPE GRAVEL #1
FROM 55 TO 75 FEET
STATIC WATER LEVEL: DATE 5/21/85
2.2' FT. ABOVE GROUND SURFACE
PUMPING WATER LEVEL 22' FT. BELOW GRADE
AFTER 2 HOURS AT 62.5 GPM.

WELL HEAD COMPLETION:
TYPE: RITLESS ADAPTOR
OTHER By approval
24 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N/A
RATED CAPACITY (GPM)
PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?
A. AT LEAST 5' FROM ANY OVERHANG YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)
SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 75' FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

RECEIVED
JUN 6 1985
WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Fine tan sand	1	4
Med. white sand	4	64
Med. tan sand	64	76
Med. tan sand w/ white clay	76	80

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 1 PAGES
COMPANY NAME Debrisys Drilling Company
SIGNATURE OF DRILLER IN CHARGE: Paul McCarney DATE 6/1/85