300

Ph 15-1

WRD-2
7/68

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

RECEIVED
NOV 27 1968
STATE OF DELAWARE
WATER RESOURCES DIVISION

Edward J Green
Short Hills Development
on Del # 498

WELL COMPLETION REPORT

1. Permit Number: _____

2. Well Depth 32 ft.

   Date Completed Aug 21, 1968

3. Grout: Type _____

   from ____ ft. to ____ ft.

4. Casing:

   2 in. to 28 ft.

   ____ in. to ____ ft.

   Drive shoe? Yes ___ No ✓

5. Screen:

   28 ft. to 32 ft.

6. Well Head Completion:

   ____ Pitless Adapter

   12 inches above grade

7. Static Water Level:

   4½ feet below grade

8. Pumping Level:

   26 ft. after 2 hrs.

   at 50 GPM

9. Type of Permanent Pump:

   Reciprocating ___ Jet ___

   Submersible ___ Other ___

   Capacity: _____ GPM

10. If well was electric or gamma logged submit copies of the log with this report.

11. Well Log

Formation	Thickness of Stratum	Depth to bottom of Stratum
Humus	1'	1'
Brown sand	3'	4'
white fine to medium sand and smoky	5'	9'
fine to coarse white sand	16'	25'
fine to coarse clean yellow sand	7'	32'
silt and dirty clayey fine to medium coarse white sand	8	40

12. Well Number _____
    (leave blank)

13. Signature of Water Well Contractor

    Paul E White

    Date Sept 4, 1968

(over)