Ph25-13

Water Well Contractors

TOMER Indian River Volunteer Fire Company JOB ~~XXXX~~ 3277

RESS Millsboro, Delaware. DATE 5/6/76

ATION 15' W. of road and 50' N. W. of Fire house Permit# 35301



FEET FROM GROUND SURFACE 0 TO.....	WELL LOG
0-1	top soil
1-18	fine to med. brown sand w/clay ~~xxxx~~ layers
18-39	fine to coarse brown sand
39-91	fine to coarse tan sand w/gravel
91-100	fine sand w/clay layers

NO. 1	DIAMETER OF WELL 6"	DEPT. OF WELL 88'
PUMPED 2 1/2	SLOT SIZE .020	TYPE OF CASING Steel
ITY G.P.M. 60	DRILLING MACHINE NO. D-1	LENGTH OF CASING 68'
STATIC LEVEL 11	DRILLER Ed Kelley	DISTANCE TO TOP OF SCREEN 68-88
NG LEVEL 14	GRAVEL 2 & 3	TYPE SCREEN PVC
IC CAPACITY 20	BAGS OF CEMENT 8	SIZE OF SCREEN 6"
D WITH air & pumper	DATE WELL COMPLETED 5/6/76	
CEMENT GROUT 0-30	DRILLER'S HELPER J. Sori	Ed Kelley
GRAVEL PACKED 50-88		WELL DRILLER SIGNATURE