RECEIVED
DEC 19 2003
STATE OF DELAWARE
RECEIVED JAN 2 1969

376

WRD-2
7/68

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

Pi 12-03
[redacted]

WELL COMPLETION REPORT

James Travis

1. Permit Number: _____

2. Well Depth 70 ft.

Date Completed 12-10-68

3. Grout: Type _____

from _____ ft. to _____ ft.

4. Casing:

3 in. to 50 ft.

_____ in. to _____ ft.

Drive shoe? Yes ___ No x

5. Screen:

50 ft. to 70 ft.

6. Well Head Completion:

_____ Pitless Adapter

_____ inches above grade

7. Static Water Level:

9 feet below grade

8. Pumping Level:

25 ft. after 2 hrs.

at 60 GPM

9. Type of Permanent Pump:

Reciprocating ___ Jet ___

Submersible ___ Other ___

Capacity: _____ GPM

10. If well was electric or gamma logged submit copies of the log with this report.

11. Well Log

Formation	Thickness of Stratum	Depth to bottom of Stratum
top soil	0-1	
tan sand w/ clay	1-5	
fine-coarse tan sand	5-14	
tan sand w/ gravel	14-26	
fine-coarse tan sand	26-28	
tan sand w/ gray clay	28-38	
tan sand w/ gravel	38-70	
tan sand w/ gravel & multi clays	70-78	
gray clay	78-80	

12. Well Number _____
(leave blank)

13. Signature of Water Well Contractor

Delmarva Drilling Co., Inc.

Date 12-18-68

(over)