

WELL COMPLETION REPORT

110-00

1. Permit Number: 25325  
 Owner of Well: Bogard B. Brown

2. Test Well  
 Observation Well   
 Production Well   
 Well Abandoned? Yes  No

3. Total Well Depth 35 feet  
 Date Completed Jan 16, 1976

4. Grout: Type None  
 from      foot to      feet  
 from      foot to      feet

5. Casing: Type Galv. Steel  
2 inches to 31 feet  
     inches to      feet  
 Drive Shoe? Yes  No

6. Screen Setting:  
31 feet to 35 feet

7. Gravel Packed? Yes  No   
30 feet to 35 feet

8. Well Head Completion:  
 Pitless Adapter      Type  
12 inches above grade

9. Static Water Level:  
4 feet below grade  
     feet above grade

10. Pumping Water Level:  
24 feet below grade after  
2 hours at 55 GPM

11. Permanent Pump Installed?  
 Yes  No   
 a. Shallow Well   
    Deep Well   
 b. Reciprocating  Rotary   
    Centrifugal  Jet   
    Submersible   
 c. Capacity      GPM

12. Well Number       
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil	1	1
brownish yellow fine & medium sand	3	4
white fine & medium sand	4	8
very light yellow fine to coarse sand	6	14
dirty white silt with fine & med sand	3	17
fine to coarse fairly clean light yellow sand	8	25
yellow fine to coarse fairly clean sand	6	31
white fine to coarse fairly clean sand	4	35

14. Signature of Water Well Contractor Paul E. White & Division Date Jan 19, 1976

(over)