

MAIL TO:
WATER SUPPLY BRANCH
DIVISION OF WATER RESOURCES
P.O. BOX 1401
DOVER, DELAWARE 19903

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED 21 DAYS AFTER
CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 65146 LOCAL ID _____

OWNER Klenck, Robert

CONSTRUCTION DATE 6-9-86

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL N/A

ABANDONMENT METHOD N/A

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 40'

CASING SEQUENCE

	INNER	OUTER
CASING TOP	0	
CASING BOTTOM	30	
CASING DIAMETER	4"	
CASING MATERIAL	PVC	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	30	
SCREEN BOTTOM	40	
SCREEN DIAMETER	4"	
SCREEN MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AQUIFER
MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: FROM 0 TO 25 FEET

NON-GROUT BACKFILL OF WELL ANNULUS
TYPE _____ FROM _____ TO _____ FEET

GRAVEL PACK: TYPE #3
FROM 25 TO 40 FEET

STATIC WATER LEVEL: DATE 6-9-86
4 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 10 FT. BELOW GRADE
AFTER 2 1/2 HOURS AT 60 GPM.

WELL HEAD COMPLETION:

TYPE: FITLESS ADAPTOR
OTHER
12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE Grundfos SS SUB

RATED CAPACITY (GPM) 20-30

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

A. AT LEAST 5' FROM ANY OVERHANG YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE YES NO
OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS NO FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN
ON APPLICATION FORM? YES NO

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED

APR 14 1987

WATER SUPPLY

PS-1-13

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Fine Sand & Clay	1	12
Fine To Coarse Sand	12	41
Fine Sand w/Clay	41	43

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 1 PAGES
COMPANY NAME AWWS
SIGNATURE OF DRILLER IN CHARGE: E. Kaufman DATE 4-8-87