

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 89528 LOCAL ID _____

OWNER Tunnell Companies, L.P.

P.O. Box 368, Millsboro, DE 19966

CONSTRUCTION DATE 03/31/92

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 110'

CASING SEQUENCE

CASING TOP
 CASING BOTTOM
 CASING DIAMETER
 CASING MATERIAL

INNER	OUTER
<u>+2'</u>	
<u>0.3'</u>	
<u>8"</u>	
<u>PVC</u>	

SCREEN SEQUENCE

SCREEN TOP
 SCREEN BOTTOM
 SCREEN DIAMETER
 SCREEN MATERIAL

INNER	OUTER
<u>8"</u>	
<u>110'</u>	
<u>8"</u>	
<u>S.S.</u>	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQUI-
 FER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 0 TO 60 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE _____ FROM _____ TO _____ FEET

GRAVEL PACK: TYPE #2

FROM 65 TO 115 FEET

STATIC WATER LEVEL: DATE 3/31/92

11 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 14 FT. BELOW GRADE

AFTER 1 HOURS AT 100 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER CAPPED

24 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE n/a

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

A. AT LEAST 15' FROM ANY FOUNDATION YES NO
 B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
 C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)


SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS 100' FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Brown clay	1	5
Tan fine to med sand	5	19
White clay	19	30
Tan fine to coarse sand w/gravel		
Tan fine to coarse sand w/gravel	80	115
Gray clay	115	118
Tan fine to coarse sand	118	121

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME American Water Well Systems, Inc.

SIGNATURE OF DRILLER IN CHARGE: Cabin Wm. Wallace DATE 5/20/92