

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

WELL COMPLETION REPORT

Pi 34-2

1. Permit Number: Test hole (no permit)
 Owner of Well: Linford P. Fawcett
on Sussex County Route # 22 near Morris

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 72 feet
 Date Completed Dec. 21, 1971

4. Grout: Type _____
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type galv steel
2 inches to 68 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
68 feet to 72 feet

7. Gravel Packed? Yes No
64 feet to 72 feet

8. Well Head Completion:
 _____ Pitless Adapter _____ Type
 _____ 12 inches above grade

9. Static Water Level:
 _____ 15 1/2 feet below grade
 _____ feet above grade

10. Pumping Water Level:
 _____ 29 feet below grade after
 _____ 2 hours at _____ 33 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

RPA 10'

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
sandy top soil	6"	6"
very sandy clay subsoil	3'-6"	4
very fine to coarse tan-yellow sand	8	12
light yellow sandy clay	17	29
very fine to very coarse light yellow sand, dirty with pieces of sandy clay	9	38
very fine to very coarse white and some light yellow sand (mostly medium coarse sand)	26	64
very fine to very coarse white and some light yellow sand, fairly clean, (and some small gravel)	20	84
same as 64'-84'	31	115

14. Signature of Water Well Contractor Paul E. White Date Jan 5, 1971