

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

Pi 34-17

WELL COMPLETION REPORT

Well 5-B

1. Permit Number: 35470
 Owner of Well: Indian Landing M.H. Park

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 30 feet
 Date Completed Jan 19, 1976

4. Grout: Type Cement
 from 15 feet to 2 feet
 from feet to feet

5. Casing: Type Galv. Steel
2 inches to 26 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
26 feet to 30 feet

7. Gravel Packed? Yes No
25 feet to 30 feet

13. Well Log

8. Well Head Completion:
 Pitless Adapter Type
12 inches above grade

9. Static Water Level:
4 feet below grade
 feet above grade

10. Pumping Water Level:
26 feet below grade after
2 hours at 40 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

50 PPM NACL after
 2 hrs.

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil	1	1
brownish yellow fine + medium sand	3	4
light yellow clayey sand	4	8
white sandy clay	8	16
fine to coarse fairly clean white sand	8	24
slightly dirty white fine to coarse sand	3	27
fine to coarse fairly clean white sand	5	32

14. Signature of Water Well Contractor Paul C. White + Sons inc. Date Jan. 19, 1976