

STATE OF DELAWARE  
 WATER AND AIR RESOURCES COMMISSION  
 Water Resources Division  
 Dover, Delaware 19901

P. 34-18

WRD-2  
 7/69

12

WELL COMPLETION REPORT

Abandoned

Test Well #6

1. Permit Number: 35476  
 Owner of Well: Jordan Funding M.H. Park

2. Test Well 1  
 Observation Well      
 Production Well      
 Well Abandoned? Yes     No    

3. Total Well Depth 30 feet  
 Date Completed Dec 24, 1975

4. Grout: Type Cement  
 from 20 feet to 0 feet  
 from     feet to     feet

5. Casing: Type Galv. Steel  
2 inches to 26 feet  
    inches to     feet  
 Drive Shoe? Yes     No 1

6. Screen Setting:  
26 feet to 30 feet

7. Gravel Packed? Yes 1 No      
25 feet to 30 feet

8. Well Head Completion:  
    Pitless Adapter     Type  
12 inches above grade

9. Static Water Level:  
5 feet below grade  
    feet above grade

10. Pumping Water Level:  
26 feet below grade after  
2 hours at 45 GPM

11. Permanent Pump Installed?  
 Yes     No      
 a. Shallow Well      
 Deep Well      
 b. Reciprocating     Rotary      
 Centrifugal     Jet      
 Submersible      
 c. Capacity     GPM

12. Well Number      
 (Leave Blank)

50 P.P.M. NACL.  
after 3 1/2 hrs pumping

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	1	1
brownish yellow fine & medium sand	3	4
light yellow clayey sand	4	8
white sandy clay	8	16
fine to coarse fairly clean white sand	8	24
slightly dirty white fine to coarse sand & gravel	3	27
fine to coarse fairly clean white sand	5	32

14. Signature of Water Well Contractor Paul E. White & Sons Inc. Date Dec. 24, 1975