

EL-28'
SHA

WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

DB 35-6

WELL COMPLETION REPORT

1. Permit Number: 39183
Owner of Well: Nelson D. Bennett

2. Test Well _____
Observation Well _____
Production Well
Well Abandoned? Yes _____ No

3. Total Well Depth 103 feet
Date Completed 11-29-77

4. Grout: Type Portland
from 3 feet to 93 feet
from _____ feet to _____ feet

5. Casing: Type PVC
0 inches to 33 feet
_____ inches to _____ feet
Drive Shoe? Yes _____ No

6. Screen Setting:
93 feet to 103 feet

7. Gravel Packed? Yes No _____
20 feet to 103 feet

8. Well Head Completion:
NO Pitless Adapter _____ Type _____
_____ inches above grade

9. Static Water Level:
8 feet below grade
_____ feet above grade

10. Pumping Water Level:
22 feet below grade after
4 hours at 600 GPM

11. Permanent Pump Installed?
Yes _____ No
a. Shallow Well _____
Deep Well _____
b. Reciprocating _____ Rotary _____
Centrifugal _____ Jet _____
Submersible _____
c. Capacity _____ GPM

12. Well Number _____
(Leave Blank)

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
Light Sand - Med. fine	1	6
Heavy Clay	6	7
1/2" to 3/4" Sandy clay	7	15
Light Sand - Med. coarse	15	30
Light Sand - Med. fine	30	45
Light Sand - Med.	45	50
Heavy Clay	50	53
Light Sand - Med. coarse	53	60
Light Sand - Med. coarse	60	90
Light Sand - Med.	90	103

Signature of Water Well Contractor: Ideas Well Drilling
Date: 11-12-77