

Use this one

EI-38'  
SNA

Q644-06

STATE OF DELAWARE  
WATER AND AIR RESOURCES COMMISSION  
Water Resources Division  
Dover, Delaware 19901

WRD-2  
7/69

WELL COMPLETION REPORT

1. Permit Number: 31472  
Owner of Well: Radio Bros

2. Test Well  
Observation Well   
Production Well   
Well Abandoned? Yes  No

3. Total Well Depth 110 feet  
Date Completed 3/20/74

4. Grout: Type Cement  
from 3 feet to 15 feet  
from      feet to      feet

5. Casing: Type 4" PVC  
0 inches to 90 feet  
     inches to      feet  
Drive Shoe? Yes  No

6. Screen Setting:  
70 feet to 110 feet

7. Gravel Packed? Yes  No   
110 feet to 60 feet

8. Well Head Completion:  
 Electric Adapter  Cup Type  
     inches above grade

9. Static Water Level:  
12 feet below grade  
     feet above grade

10. Pumping Water Level:  
85 feet below grade after  
5 hours at 500 GPM

11. Permanent Pump Installed?  
Yes  No   
a. Shallow Well   
    Deep Well   
b. Reciprocating  Rotary   
    Centrifugal  Jet   
    Submersible   
c. Capacity      GPM

12. Well Number       
(Leave Blank)  
12" hole direction well

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Brown top soil	0	3
Sandy silt	3	9
Thin sandy clay	9	35
Thin clay	35	55
Thin to med. fine sand	55	75
Med. to medium coarse	75	95
Coarse	95	110
Clay		

14. Signature of Water Well Contractor      Title       
Robert W. Anderson