

EI-44!
SHA

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WRD-2
7/69

Qb55-15

WELL COMPLETION REPORT

1. Permit Number: 36433
Owner of Well: Carl Harrington

2. Test Well
Observation Well
Production Well
Well Abandoned? Yes No

3. Total Well Depth 35 feet
Date Completed 7-10-76

4. Grout: Type Current
from 3 feet to 12 feet
from feet to feet

5. Casing: Type PVC
0 inches to 30 feet
 inches to feet
Drive Shoe? Yes No

6. Screen Setting:
30 feet to 35 feet

7. Gravel Packed? Yes No
28 feet to 35 feet

8. Well Head Completion:
W Pileless Adapter Type
 inches above grade

9. Static Water Level:
10 feet below grade
 feet above grade

10. Pumping Water Level:
18 feet below grade after
1 hour at 70 GPM

11. Permanent Pump Installed?
Yes No
a. Shallow Well
 Deep Well
b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
c. Capacity GPM

12. Well Number
(Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soils	0	1
yellow sand	1	4
brown clay	4	10
to brown sand med.	10	15
brown sand red	15	35

14. Signature of Water Well Contractor Dean Will Miller Date 7-15-76