MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST BE RETURNED WITHIN 30 DAYS OF CONSTRUCTION DATE

FORMATION LOG

Qc43-08

PAGE 1 OF 1 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 167376-W | LOCAL ID#

PROPERTY OWNER Alfred Evans

WELL CONTRACTOR American Water Well Systems, Inc. | LIC# 608

DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0'	1'
White Clay	1'	13'
White fine to coarse	13'	25'
Tan fine to coarse with gravel	25'	68'
Tan gravel Tbd	68'	86'
Tan fine to coarse Tbt	86'	128'
Gray clay	128'	130'
Gray fine to coarse Tcatb	130'	155'

OTHER COMMENTS:

RECEIVED
OCT 19 1999
WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge | License# 608 | Date 10/15/99

White - DNREC • Canary - Contractor • Pink - Owner

Doc. No. 40-08-82-12-11