



IF BEING INSTALLED AND PERMITS REQUIRED IN ADDITION TO THIS APPLICATION WELL PERMIT REPORT MUST BE FILED WITH THE BRANCH WITHIN TWENTY DAYS AFTER COMPLETION OF THIS WELL. FAILURE TO DO SO MAY RESULT IN PENALTY.



LOCATION TO ROADS AND UTILITIES

OWNER
OLIVER

LOCAL PROPERTY LINE, CROSS UTILITY PLAT



PERMIT NO. 65598
SEPTIC

IN PERMISSION IS HEREBY GRANTED AND SUBJECT TO THOSE LAWS GOVERNING WELL PERMITS

65598

WELL CONTRACTOR

MAIL TO:
WATER SUPPLY BRANCH
DIVISION OF WATER RESOURCES
P.O. BOX 1401
DOVER, DELAWARE 19903

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST BE RETURNED 21 DAYS AFTER CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT
PERMIT NO. 65598 LOCAL ID _____

OWNER Incl. Albert R. Jr.

CONSTRUCTION DATE 6-26-76
PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
ABANDONMENT DATE FOR OLD WELL 6-26-76
ABANDONMENT METHOD alay

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____
TOTAL DEPTH DRILLED 55'

CASING SEQUENCE

DEPTH	DIAMETER	MATERIAL
0	4.5"	PVC
2	2"	

SCREEN SEQUENCE

DEPTH	DIAMETER	MATERIAL
0	4.5"	
2	2"	PVC

GROUT TYPE: CEMENT BENTONITE CLAY
OTHER: _____
FROM 0 TO 20 FEET
NON-GROUT BACKFILL OF WELL ANNULUS
TYPE _____ FROM _____ TO _____ FEET
GRAVEL PACK: TYPE 2
FROM 35 TO 60 FEET

STATIC WATER LEVEL: DATE 6-26-76
86" FT. (Below, above) GROUND SURFACE
PUMPING WATER LEVEL: 25 FT. BELOW GRADE
AFTER 1 1/2 HOURS AT 22 GPM

WELL HEAD COMPLETION:
TYPE: FITLESS ADAPTOR
OTHER capped
_____ INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N/A
RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?
A. AT LEAST 5' FROM ANY OVERHANG YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN BSEWER LINE YES NO
D. AT LEAST 10' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)
SEPTIC TANK FIELD CESSPOOL OR PRIVY
IS _____ FROM COMPLETED WELL
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

Q-57-018
RECEIVED
APR 14 1987
WATER SUPPLY

DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Tan Fine Sand	1	7
Tan Fine to med. Sand w/ clay	7	10
White Fine to med. Sand w/ clay	10	25
White Fine to med. Sand	25	38
Tan Fine to med. Sand	38	45
Tan Fine to med. Sand	45	60

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF _____ PAGES
COMPANY NAME WWS
SIGNATURE OF DRILLER IN CHARGE _____ DATE _____