

DELMARVA DRILLING COMPANY  
 WATER AND AIR POLLUTION CONTROL  
 Water Resources Division  
 Dover, Delaware 19901

WELL COMPLETION REPORT



1. Permit Number: WR-6-302/1971  
 Owner of Well: Bruce Green

2. Test Well  
 Observation Well       
 Production Well XX  
 Well Abandoned? Yes      No     

3. Total Well Depth 50 feet  
 Date Completed 4/12/71

4. Grout: Type       
 from      feet to      feet  
 from      feet to      feet

5. Casing: Type Sch 40 PVC  
2 inches to 40 feet  
     inches to      feet  
 Drive Shoe? Yes      No     

6. Screen Setting:  
40 feet to 50 feet

7. Gravel Packed? Yes X No       
34 feet to 50 feet

8. Well Head Completion:       
     Pitless Adapter       
     inches above grade

9. Static Water Level:  
18 feet below grade  
     feet above grade

10. Pumping Water Level:  
25 feet below grade after  
2 hours at 12 GPM

11. Permanent Pump installed?  
 Yes      No XX  
 a. Shallow Well       
 Deep Well       
 b. Reciprocating      Rotary       
 Centrifugal      Jet       
 Submersible       
 c. Capacity      GPM

12. Well Number       
 (Leave Blank)

Qd 21-23

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	1	1
fine to med brown sand	6	7
fine to med tan sand	9	16
gray clay	2	18
fine to coarse tan sand	11	29
fine to coarse white sand	11	40
fine to coarse brown sand	10	50

14. Signature of Water Well Contractor DELMARVA DRILLING CO., INC. Date April 29, 1971