

STATE OF DELAWARE
 WATER SUPPLY BRANCH
 DIVISION OF ENVIRONMENTAL CONTROL
 P.O. BOX 1881
 DOVER, DELAWARE 19903

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 21 DAYS AFTER
 CONSTRUCTION DATE

WELL COMPLETION REPORT

CLASSIFICATION

PERMIT NO. 63447 LOCAL ID 1-1

OWNER Horace Peoples

CONSTRUCTION DATE 12-30-85

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD
 AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 100

CASING SEQUENCE

DEPTH	DIAMETER	MATERIAL
0	12	4" Schedule 40
2	12	4" Schedule 40
100	12	4" Schedule 40

SCREEN SEQUENCE

DEPTH	DIAMETER	MATERIAL
0	12	4" Schedule 40
2	12	4" Schedule 40
100	12	4" Schedule 40

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

NON-GROUT BACKFILL OF WELL ANNULUS TYPE: _____ FROM _____ TO _____ FEET

GRAVEL PACK: TYPE _____ FROM _____ TO _____ FEET

STATIC WATER LEVEL: DATE 12-30-85

PUMPING WATER LEVEL: _____ FT. BELOW GRADE

AFTER _____ HOURS AT _____ GPM.

WELL HEAD COMPLETION:
 TYPE: FILLER ADAPTOR
 OTHER _____
 _____ INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE ?

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?
 A. AT LEAST 5' FROM ANY OVERHANG YES NO
 B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
 C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS _____ FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

Qd35-01

WATER SUPPLY

DRILLERS LOG-DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
100' D.I.L.	0	1
fine fine sand	1	8
course fine sand	5	15
medium fine sand	15	25
sand & clay	25	30
course fine sand	30	78
course fine sand	78	95
course fine sand	95	100
fine clay sand	100	125

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF _____ PAGES
 COMPANY NAME Water Well Supply
 SIGNATURE OF DRILLER IN CHARGE _____ DATE _____

REVISIONS 05-10-85-10-81-83

WHITE - DRIBER

CANARY - CONTRACTOR

PINK - OWNER