

2503

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

Qd 41-3

WELL COMPLETION REPORT

1. Permit Number: 518-71
 Owner of Well: Pet E. Culver

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 60 feet
 Date Completed 6/15/71

4. Grout: Type _____
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type Sch 40 PVC
4" inches to 50 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
50 feet to 60 feet

7. Gravel Packed? Yes No
40 feet to 60 feet


8. Well Head Completion:
 Pitless Adapter _____ Type _____
 _____ inches above grade

9. Static Water Level:
11 feet below grade
 _____ feet above grade

10. Pumping Water Level:
20 feet below grade after
2 hours at 60 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)



13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	1	1
fine to med tan sand	6	7
white clay w/sand layers	14	21
fine to coarse tan sand w/small clay layers	29	50
fine to coarse brown sand	14	64

14. Signature of Water Well Contractor DELMARVA DRILLING CO., INC. Date June 23, 1971
 P. O. BOX 125
 BRIDGEVILLE, DELAWARE 19933

(over)