

MAIL TO:

WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1401
DOVER, DELAWARE 19903

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED 30 DAYS AFTER
CONSTRUCTION DATE

WELL COMPLETION REPORT

LEASE PRINT

PERMIT NO. 82503 LOCAL ID 14

OWNER Delmarva Drilling

CONSTRUCTION DATE 7/6/90

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED _____

CASING SEQUENCE

CASING TOP
CASING BOTTOM
CASING DIAMETER
CASING MATERIAL

	INNER	OUTER
CASING TOP	2'	
CASING BOTTOM	108'	
CASING DIAMETER	4"	
CASING MATERIAL	PVC	

SCREEN SEQUENCE

SCREEN TOP
SCREEN BOTTOM
SCREEN DIAMETER
SCREEN MATERIAL

	INNER	OUTER
SCREEN TOP	108'	
SCREEN BOTTOM	78'	
SCREEN DIAMETER	4"	
SCREEN MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AQUIFER
MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 0 TO 58 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE N/A FROM _____ TO _____ FEET

GRAVEL PACK: TYPE MARIC #1

FROM 78' TO 58 FEET

STATIC WATER LEVEL: DATE 7/6/90

7 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 12 FT. BELOW GRADE

AFTER 1.5 HOURS AT 100 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER _____

12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE/ GOULDS

RATED CAPACITY (GPM) 10

PUMP INTAKE SETTING 25 FT. BELOW GRADE

THE COMPLETED WELL IS?

A. AT LEAST 15' FROM ANY FOUNDATION YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)


SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS 100' FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



Qd52-06

DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Dark sand w/ streaks of clay	1	19
Fine to med. tan sand	19	34
3 in. coarse tan sand	34	80

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME Delmarva Drilling Co.

SIGNATURE OF DRILLER IN CHARGE: Bill Coughlin

DATE

7/6/90