


35967

MUST BE OBTAINED PERMIT BEFORE DRILLING

1976 Year
1976
1



RECEIVED
MAY 12 1976

STATE OF DELAWARE
WATER RESOURCES SECTION

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WRD-2
7/69

WELL COMPLETION REPORT

1. Permit Number: 35967
 Owner of Well: Morison H. Atkins

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 69 feet
 Date Completed May 6, 1976

4. Grout: Type NONE
 from feet to feet
 from feet to feet

5. Casing: Type Galv. Steel
2 inches to 6.5 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
65 feet to 69 feet

7. Gravel Packed? Yes No
60 feet to 69 feet

8. Well Head Completion:
 Pitless Adapter Type
12 inches above grade

9. Static Water Level:
5 feet below grade
 feet above grade

10. Pumping Water Level:
24 feet below grade after
2 hours at 60+ GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

Qe 43-03

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	1	1
clayey sub soil	3	4
alg. white and yellow clay	13	17
very fine to very coarse clay yellow and white sand	13	30
very fine to coarse yellow sand, very silty	10	40
very fine to very coarse yellow sand, small gravel	7	47
same, light yellow	9	56
very fine sand fine and fine light yellow sand	8	64
fine to very coarse yellow sand, small gravel	5	69
very fine to very coarse light yellow sand, silt	4	73

14. Signature of Water Well Contractor Date
Paul E. White - Dover, Del. May 8, 1976
F.W.

(over)

RECEIVED
 4 1976
 DELAWARE
 WATER RESOURCES SECTION
 Permit No. 35967
 well as per
 The following
35967
5/8/76