

MAIL TO:
 WATER SUPPLY DIVISION
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL
 101 BAY STREET
 DOVER, DELAWARE 19901

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE FILED WITH THE STATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 123456 LOCAL ID 101

OWNER Henry

CONSTRUCTION DATE 2-22-85

PURPOSE TEST PERMANENT

USE DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify)

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify)

TOTAL DEPTH DRILLED 101

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP				
CASING BOTTOM				
CASING DIAMETER				
CASING MATERIAL				

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP				
SCREEN BOTTOM				
SCREEN DIAMETER				
SCREEN MATERIAL				

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE ROW
 IF SA MUST BE OBTAINED FROM DNREC

GROUT TYPE CEMENT PORTLAND CEMENT CLAY
 OTHER
 FROM 3 TO 20 FEET
 NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE None TO _____ FEET
 GRAVEL PACK TYPE None
 FROM 20 TO 101 FEET
 STATIC WATER LEVEL DATE 2-22-85
 6 FT ABOVE GROUND SURFACE
 PUMPING WATER LEVEL _____ FT BELOW GRADE
 AFTER _____ HOURS AT _____ GPM

WELL HEAD COMPLETION:

TYPE INLETS ADAPTOR
 OTHER
12" INLETS ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:


EQUIP. MANUFACTURER ?
 RATED CAPACITY (GPM) ?
 PUMP INTAKE SETTING _____ FT BELOW GRADE

THE COMPLETED WELL IS?

YES NO
 A AT LEAST 5' FROM ANY OVERHANG
 B AT LEAST 50' FROM ANY SEPTIC TANK
 C AT LEAST 10' FROM TOWN SEWER LINE
 D AT LEAST 100' FROM THE NEAREST EDGE
 OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR DRIVE
 IS _____ FROM COMPLETED WELL
 IS COMPLETED WELL LOCATED A "SHOCK"
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS



Qe 51-05

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Topsoil	0	1
Tan Clay	1	8
White Clay	8	15
Coarse tan Sand	15	35
Coarse White Sand	35	50
Coarse tan Sand	50	60
Gravel	60	63
Coarse Tan Sand	63	73
Gray Clay	73	80
Coarse tan Sand	80	101

SUPPLEMENTAL DRILLERS LOG ATTACHED? YES NO
 PAGE 1 OF _____
 COMPANY NAME Super Well Drilling
 SIGNATURE OF DRILLER [Signature] DATE _____