

In computers

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

10279

WELL COMPLETION REPORT

WRD-2
7/69

Qg 14-42

#5

1. Permit Number: 30081
 Owner of Well: National Cash Register
 Type Pitless Adapter inches above grade DONE

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 24' feet
 Date Completed 8/14/73

4. Grout: Type DONE
 from feet to feet
 from feet to feet

5. Casing: Type PVC
2 inches to 19' feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting: 19 feet to 24 feet

7. Gravel Packed? Yes No
15 feet to 24 feet

8. Well Head Completion:
 Pitless Adapter inches above grade DONE

9. Static Water Level:
13 feet below grade
 feet above grade

10. Pumping Water Level:
25 feet below grade after 17 GPM
21 hours at GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number GPM
 (Leave Blank) Drilled 2nd

Well Location:
#5 as per letter dated July 19, 1973 from Frank Moore North Corner of ~~the~~ plant

13. Well Log	Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil		0	1
Gray clay		1	10
fine-coarse tan sand		10	25

14. Signature of Water Well Contractor Dulmarva Culling Date October 10, 1973

(over)