

1. Permit Number: 25-466
 Owner of Well: Antoine Thomas
 Type: Noneless Adapter
8 inches above grade

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No ✓

3. Total Well Depth 42 feet
 Date Completed 2-17-16

4. Grout: Type None
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC
0 inches to 42 feet
 inches to feet
 Drive Shoe? Yes No ✓

6. Screen Setting:
37 feet to 42 feet

7. Gravel Packed? Yes NO
37 feet to 42 feet

8. Well Head Completion:
Noneless Adapter
8 inches above grade
 Type

9. Static Water Level:
14 feet below grade
 feet above grade

10. Pumping Water Level:
42 feet below grade after
 hours at 60 GPM

11. Permanent Pump Installed?
 Yes No ✓
 a. Shallow Well
 Deep Well
 b. Perforating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM
 12. Well Number
 (Leave Blank)

13. Well Log	Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>fine white sand</u>		<u>4'</u>	<u>4'</u>
<u>clay</u>		<u>5'</u>	<u>9'</u>
<u>medium white sand</u>		<u>11'</u>	<u>20'</u>
<u> " brown "</u>		<u>5'</u>	<u>25'</u>
<u>coarse lite "</u>		<u>13'</u>	<u>38'</u>
<u>" brown "</u>		<u>4'</u>	<u>42'</u>

14. Signature of Water Well Contractor W. H. Rumba Date 2-18-16