

10000
 Joint Farm Assoc.
 COUNTY W/00
 CITY (PERMANENT)
 DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____
 REPLACEMENT WELL? YES NO
 (MENT) DATE FOR OLD WELL _____
 (MENT) METHOD _____

DRILLING METHOD
 BORED CABLE TOOL
 JETTED AIR ROTARY
 ROTARY REVERSE WASHED
 R (Specify) _____
 DEPTH DRILLED 220'

CASING SEQUENCE

TOP	INNER	OUTER
	+2	
BOTTOM	259	
DIAMETER	6"	
MATERIAL	PVC	

SCREEN SEQUENCE

TOP	INNER	OUTER
	259	
BOTTOM	279	
DIAMETER	6"	
MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQU-
 IFER MUST BE OBTAINED FROM DNREC.

TYPE: CEMENT BENTONITE CLAY
0 TO 220 FEET
 OUT BACKFILL OF WELL ANNULUS
 FROM _____ TO _____ FEET
 PACK: TYPE
220 TO 270 FEET
 WATER LEVEL: DATE 1/1/88
 (Below/above) GROUND SURFACE
 WATER LEVEL: 21 FT. BELOW GRADE
10 HOURS AT 50 GPM.

LEAD COMPLETION:
 TLESS ADAPTOR

 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:
 PUMP MANUFACTURER
 RATED CAPACITY (GPM)
 PUMP INTAKE SETTING FEET BELOW GRADE
THE COMPLETED WELL IS?
 YES NO
 A AT LEAST 15' FROM ANY FOUNDATION
 B AT LEAST 50' FROM ANY SEPTIC TANK
 C AT LEAST 10' FROM TOWN SEWER LINE
 D AT LEAST 100' FROM THE NEAREST EDGE
 OF ANY TILE FIELD
THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC/TILE FIELD CESSPOOL OR PRIVY
 IS 15' FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED
 JAN 18 1988
 WATER SUPPLY
 Q423-10

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Fn snd	1	4
clay	4	6
Fn/md snd	6	26
Fn/crse snd	26	96
Iron ore	96	97
Gry clay	97	110
Fn/crse snd & grvl	110	155
Fn snd & clay	155	180
Fn snd	180	200
Gry clay	200	210
Fn/md snd	210	241
Fn/crse gry snd	241	279
Fn/md snd	279	281
Gry clay	281	290

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF _____ PAGES
 COMPANY NAME American Water Well Systems
 SIGNATURE OF DRILLER IN CHARGE: Ed Kelley DATE _____