

Qh24-18

1. Permit Number: 39245
Owner of Well: Ocean View Real Estate

2. Test Well
Observation Well
Production Well
Well Abandoned? Yes No

3. Total Well Depth 55 feet
Date Completed 8-17-77

4. Grout: Type NONE
from feet to feet
from feet to feet

5. Casing: Type 2" PVC
0 inches to 55 feet
 inches to feet
Drive Shoe? Yes No

6. Screen Setting:
50 feet to 55 feet

7. Gravel Packed? Yes No
50 feet to 55 feet

8. Well Head Completion: yes Pitless Adapter Baker Type
 inches above grade

9. Static Water Level:
12 feet below grade
 feet above grade

10. Pumping Water Level:
16 feet below grade after
2 hours at 30 GPM

11. Permanent Pump Installed?
Yes No
a. Shallow Well
 Deep Well
b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
c. Capacity GPM

12. Well Number
(Leave Blank)

Qh24-18

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Coarse white sand	20'	20'
medium " "	20'	40'
Coarse " "	15'	55'

Signature of Water Well Contractor
Buane

Date 8-18-77