

MAIL TO:

WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1401
DOVER, DELAWARE 19903

**STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL**

WELL COMPLETION REPORT MUST
BE RETURNED 30 DAYS AFTER
CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 99827 LOCAL ID _____

OWNER Theodore Elzer

CONSTRUCTION DATE 5-23-94

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 40'

CASING SEQUENCE

	INNER	OUTER
CASING TOP	8" above	
CASING BOTTOM	35'	
CASING DIAMETER	2"	
CASING MATERIAL	poly pvc	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	35'	
SCREEN BOTTOM	40'	
SCREEN DIAMETER	2"	
SCREEN MATERIAL	DVC	

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AQU-
IFER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY
OTHER: _____

FROM 33' TO 0' FEET

NON-GROUT BACKFILL OF WELL ANNULUS
TYPE sand FROM 33' TO 35' FEET

GRAVEL PACK: TYPE pea
FROM 35' TO 40' FEET

STATIC WATER LEVEL: DATE 5-23-94
10 FT. (Below) above) GROUND SURFACE

PUMPING WATER LEVEL: 12 FT. BELOW GRADE
AFTER 2 HOURS AT 25 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR
OTHER capped
8 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:


PUMP MANUFACTURE n/a
RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

	YES	NO
A. AT LEAST 15' FROM ANY FOUNDATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B. AT LEAST 50' FROM ANY SEPTIC TANK	<input checked="" type="checkbox"/>	<input type="checkbox"/>
C. AT LEAST 10' FROM TOWN SEWER LINE	<input checked="" type="checkbox"/>	<input type="checkbox"/>
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	<input checked="" type="checkbox"/>	<input type="checkbox"/>

THE NEAREST NEIGHBORS (CIRCLE ONE)

(SEPTIC) TILE FIELD CESSPOOL OR PRIVY
IS 100' FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN
ON APPLICATION FORM?
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



Qh32-03

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top sand	0'	5'
white sand	5'	20'
tan sand	20'	40'

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF _____ PAGES
COMPANY NAME Jes-Co
SIGNATURE OF DRILLER IN CHARGE: Theo. Jes DATE _____