

WELL COMPLETION REPORT

D. 10/24

WELL NO. 58472 LOCAL ID 319

OWNER Davis, Charles - Pyle Center

INSTALLATION DATE 10/10/84

TEST PERMANENT

DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

INSTALLMENT DATE FOR OLD WELL _____

INSTALLMENT METHOD _____

DRILLING METHOD

BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED

OTHER (Specify) _____

DEPTH DRILLED 70

CASING SEQUENCE

	1st	2nd	3rd	4th
TOP	<u>25</u>			
BOTTOM	<u>60</u>			
DIAMETER	<u>4</u>			
MATERIAL	<u>pvc</u>			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
TOP	<u>60</u>			
BOTTOM	<u>70</u>			
DIAMETER	<u>4</u>			
MATERIAL	<u>pvc</u>			

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AQUIFER
MUST BE OBTAINED FROM DNREC.

TYPE: CEMENT BENTONITE CLAY

ROUT BACKFILL OF WELL ANNULUS _____ FEET

FROM _____ TO _____ FEET

PACK: TYPE #2 well sand

60 TO 70 FEET

WATER LEVEL: DATE 10/10/84

FT. (Below, above) GROUND SURFACE _____

G WATER LEVEL: 18 FT. BELOW GRADE

2 HOURS AT 60 GPM.

HEAD COMPLETION:

PISTON ADAPTOR

INCHES ABOVE GRADE _____

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE Grundfos

RATED CAPACITY (GPM) 35

PUMP INTAKE SETTING 50 FT. BELOW GRADE

THE COMPLETED WELL IS?

	YES	NO
A. AT LEAST 5' FROM ANY OVERHANG	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B. AT LEAST 50' FROM ANY SEPTIC TANK	<input checked="" type="checkbox"/>	<input type="checkbox"/>
C. AT LEAST 10' FROM TOWN SEWER LINE	<input checked="" type="checkbox"/>	<input type="checkbox"/>
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	<input checked="" type="checkbox"/>	<input type="checkbox"/>

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS 500' FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

Q 54-08

THICKNESS

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top	<u>2</u>	<u>2</u>
sand/white	<u>4</u>	<u>6</u>
chay, brown	<u>10</u>	<u>16</u>
chay, white	<u>10</u>	<u>26</u>
chay, gray	<u>16</u>	<u>42</u>
fine sand-gray	<u>28</u>	<u>70</u>

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF _____ PAGES

COMPANY NAME Wayne C. Webb Well Drilling, Inc.

SIGNATURE OF DRILLER IN CHARGE: Wayne Webb DATE 10/10/84