TELEPHONE 302/337-8254

Delmarva Drilling Co., Inc.

P. O. BOX 188 • BRIDGEVILLE, DELAWARE 19933

Q:24-3

Water Well Contractors

CUSTOMER Whites Creek Manor JOB 3738

ADDRESS Millville, Del. DATE 5/4/77

LOCATION 20' E. of 351 and 18' W. of pool 37796



FEET FROM GROUND SURFACE 0 TO.....	WELL LOG
0-1	top soil
1-11	fine to med. brown sand
11-28	fine to coarse tan sand
28-49	fine to coarse white sand w/white clay layers
49-62	fine to coarse white sand
62-75	fine to coarse white sand w/white clay layers

WELL NO. 1	DIAMETER OF WELL 2"	DEPT. OF WELL 62'
HRS. PUMPED 1 1/2	SLOT SIZE .016	TYPE OF CASING PVC
CAPACITY G.P.M. 40	DRILLING MACHINE NO. D-2	LENGTH OF CASING 52'
STATIC LEVEL 12	DRILLER E. Kelley	DISTANCE TO TOP OF SCREEN 52-62
PUMPING LEVEL 25	GRAVEL 2 & 3	TYPE SCREEN PVC
SPECIFIC CAPACITY 3.33	BAGS OF CEMENT 0	SIZE OF SCREEN 2"
PUMPED WITH air & pumper	DATE WELL COMPLETED 5/4/77	
DEPTH OF CEMENT GROUT 0		
DEPTH GRAVEL PACKED 45-62'	DRILLER'S HELPER W. Huey	

E. Kelley
WELL DRILLER SIGNATURE