

MAIL TO:
 WATER SUPPLY BRANCH
 DIVISION OF ENVIRONMENTAL CONTROL
 P.O. BOX 1401
 DOVER, DELAWARE 19903

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 30 DAYS AFTER
 CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 71282 LOCAL ID SP

OWNER W/D Ag Engineers

CONSTRUCTION DATE 10/7/87

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD N/A

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 8.0

CASING SEQUENCE

	INNER	OUTER
CASING TOP	0'	
CASING BOTTOM	5.5'	
CASING DIAMETER	1.25"	
CASING MATERIAL	PVC	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	5.5'	
SCREEN BOTTOM	8.0'	
SCREEN DIAMETER	1.25"	
SCREEN MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQUI-
 FER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 0 TO 4.0 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE CONCRETE FROM 4 TO 8 FEET

GRAVEL PACK: TYPE N/A

FROM _____ TO _____ FEET

STATIC WATER LEVEL: DATE 10/7/87

6 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL N/A FT. BELOW GRADE

AFTER _____ HOURS AT _____ GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER PVC CAP

0 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N/A

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

YES NO
 A. AT LEAST 15' FROM ANY FOUNDATION
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS _____ FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



Q624-06

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
BROWN-COARSE F-M SAND	0	3.5'
GRAY-BLUE SILTY CLAY	3.5'	6.5'
GRAY SL. SILTY F SAND	6.5'	8.0'

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME DGS

SIGNATURE OF DRILLER IN CHARGE: _____ DATE 10/20/87