

1. Permit Number: 24410
 Owner of Well: Carroll Contract

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 49 feet
 Date Completed June 27, 1976

4. Grout: Type NONE
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type Galv. steel
~~4~~ 2 inches to 48 feet
 inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
43 feet to 49 feet

7. Gravel Packed? Yes No
41 feet to 49 feet

8. Well Head Completions:
12 inches above grade
 Type Titless Adapter

9. Static Water Level:
6 1/2 feet below grade
 _____ feet above grade

10. Pumping Water Level:
24 feet below grade after
2 hours at 30+ GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Jet
 Centrifugal _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number
 (leave blank)

Q134-14

Formation	Thickness of Stratum	Depth to Bottom of Stratum
top soil	0	0
clayey tan sand		
clayey fine white sand some lt. yellowish sand	10	15
very fine to very coarse, grayish white sand	12	19
very fine to very coarse white sand and silt	8	28
very fine to very coarse white sand and silt	11	32
small gravel (dirty)		
clayey fine to very coarse white sand (mostly fine)	11	32-33
clayey fine to very coarse white sand (mostly fine)	3	36
dirty with silt		
sand some yellow sand		
very fine to very coarse yellowish white sand (mostly fine) some silt	6	42
	9	51

14. Signature of Water Well Contractor _____ Date June 30, 1976