

75828 LOCAL ID

Andy Pelican

DATE 9/13/88 PERM PERMANENT

RESIDENTIAL AGRICULTURAL COMMERCIAL INDUSTRIAL PUBLIC DEWATERING HEAT PUMP SUPPLY

PLACEMENT WELL? YES NO DATE FOR OLD WELL METHOD

DRILLING METHOD

BORED CABLE TOOL JETTED AIR ROTARY REVERSE WASHED

DRILLED 62'

CASING SEQUENCE

INNER	OUTER
4 1/8"	
3 1/2"	
3"	
PVC	

SCREEN SEQUENCE

INNER	OUTER
50	
60	
40	
PVC	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACING MORE THAN ONE FOOTER MUST BE OBTAINED FROM DNRDC

CEMENT BENTONITE CLAY

TO 42 FEET

BACKFILL OF WELL ANNULUS FROM TO FEET

TYPE #2

TO 65 FEET

LEVEL DATE 9/13

BELOW (above) GROUND SURFACE

WATER LEVEL 10' FT. BELOW GRADE

HOURS AT 25 GPM.

AD COMPLETION: ADAPTOR

IF S ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE Grundfos
RATED CAPACITY (GPM) 15
PUMP INTAKE SETTING 60 FT. BELOW GRADE

75828 THE COMPLETED WELL IS? YES NO
A. AT LEAST 15' FROM ANY FOUNDATION
B. AT LEAST 50' FROM ANY SEPTIC TANK
C. AT LEAST 10' FROM TOWN SEWER LINE
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE) SEPTIC TILE FIELD CESSPOOL OR PRIVY IS 50' FROM COMPLETED WELL IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

NOV 3 1988

Q: 34-16

(38)

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
In fn snd	1	4
Wht & Yllw cly	4	13
Wht fn/md snd	13	40
Gry cly	40	42
In fn/crse snd	42	50
Wht fn/crse snd	50	65

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 1 PAGES
COMPANY NAME ARABIAN Water Well Systems
SIGNATURE Calvin... DATE 9/13/88