

1. Well No: Q135-17
 Owner of Well: Chambers Telephone

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 78 feet
 Date Completed _____

4. Grout: Type NONE
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type 2" PVC
0 inches to 78 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
73 feet to 78 feet

7. Gravel Packed? Yes No
73 feet to 78 feet

8. Well Head Condition
Y Pitless Adapter 7 1/2 inches above grade

9. Static Water Level:
10' feet below grade
 _____ feet above grade

10. Pumping Water Level:
12 feet below grade after
2 hours at 60 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

Q135-17

Formation	Thickness of Stratum	Depth to Bottom Stratum
fine brown sand	5'	5'
Brown clay	5'	10'
Medium white sand	10'	20'
Coarse white sand	20'	40'
fine white sand	20'	60'
Medium white sand	5'	65'
Coarse " "	13'	78'

Signature of Water Well Contractor
Burns

Date 8-25-77 (5)