Delmarva Drilling Co.

P. O. BOX 188

GEORGEVILLE, DELAWARE 19933

RECEIVED
FEB 11 1976
STATE OF DELAWARE
WATER RESOURCES SECTION

Water Well Contractors

CUSTOMER Fuhrman Enterprises JOB 2258

ADDRESS Fox Run Mobile Homes Park Ocean View, Del. DATE 6/14/74

LOCATION 96' E. of woods LH side of Park 42' S. of line permit #32001



FEET FROM GROUND SURFACE 0 TO.....	location map on back WELL LOG
0-1	Top soil
1-4	Sandy clay
4-18	Fine tan sand
18-44	Gray clay with shell
44-62	Fine to medium gray sand
62-81	Gray clay
81-120	Fine to medium gray sand

RECEIVED
FEB 17 1976
DELAWARE GEOLOGICAL SURVEY

WELL NO. 1	DIAMETER OF WELL 4"	DEPT. OF WELL 110'
HRS. PUMPED 2	SLOT SIZE .016	TYPE OF CASING PVC
CAPACITY G.P.M. 60	DRILLING MACHINE NO. D1	LENGTH OF CASING 104
STATIC LEVEL 11' 6"	DRILLER Calvin Wallace	DISTANCE TO TOP OF SCREEN 104-110
PUMPING LEVEL 20	GRAVEL #2 morie	TYPE SCREEN PVC
SPECIFIC CAPACITY 7	BAGS OF CEMENT clay 2	SIZE OF SCREEN 4"
PUMPED WITH pumper	DATE WELL COMPLETED 6/14/74	
DEPTH OF CEMENT GROUT Clay seal 5-15	DRILLER'S HELPER L. Davis	Calvin Wallace
DEPTH GRAVEL PACKED 95-115		WELL DRILLER SIGNATURE