

1. Permit Number: 207
 Owner of Well: Harris & Rogers

2. Test Well _____
 Observation Well _____
 Production Well X
 Well Abandoned? Yes _____ No ✓

3. Total Well Depth 92 feet
 Date Completed Dec 21 1977

4. Grout: Type _____
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type Galv Steel
2 inches to 29 feet
 _____ inches to _____ feet
 Drive Shoe? Yes _____ No X

6. Screen Setting:
29 feet to 33 feet

7. Gravel Packed? Yes _____ No _____
23 feet to 33 feet

8. Well Head Completion:
 Pitless Adapter _____ To
7 1/2 inches above grade

9. Static Water Level:
13 1/2 feet below grade
 _____ feet above grade

10. Pumping Water Level:
27 feet below grade after
2 hours at 15 GPM

11. Permanent Pump Installed?
 Yes _____ No _____
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

Q11-06

| Formation | Thickness of Stratum | Depth to Bottom of Stratum |
|---|----------------------|----------------------------|
| fill and top soil | 2 | 2 |
| coarse yellow orange sand & gravel | 1 | 9 |
| brown sand | 1 | 10 |
| very fine to coarse yellow sand | 5 | 15 |
| very fine to fine silty yellow sand & gravel | 13 | 28 |
| very fine to very coarse yellow sand & gravel | 5 | 33 |
| pieces of dark clay | | |

Signature of Water Well Contractor
Carl E. White & Sons, Inc.

Date
Dec 27, 1977