

Elmer Coy
 INSTRUCTION DATE 8/12/85
 USE TEST PERMANENT
 DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____
 IS A REPLACEMENT WELL? YES NO
 COMPLETION DATE FOR OLD WELL NTA
 COMPLETION METHOD N/A

DRILLING METHOD

BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED
 OTHER (Specify) _____
 TOTAL DEPTH DRILLED 80'

CASING SEQUENCE

INNER	OUTER
8" +	
7.5"	
2"	
PVC	

SCREEN SEQUENCE

INNER	OUTER
7.5"	
80"	
3"	
PVC	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQUIFER
 MUST BE OBTAINED FROM DNREC.

JOINT TYPE: CEMENT BENTONITE CLAY
 GROUT BACKFILL OF WELL ANNULUS:
NATIVE FROM 0 TO 7.5 FEET
 GRAVEL PACK: TYPE 3/32"
 FROM 7.5 TO 80' FEET
 STATIC WATER LEVEL: DATE 8/12/85
24 FT. (Below/above) GROUND SURFACE
 PUMPING WATER LEVEL: 24 FT. BELOW GRADE
 RUN 2 HOURS AT 60 GPM.

WELL HEAD COMPLETION:

PITLESS ADAPTOR

 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

- | | YES | NO |
|---|-------------------------------------|--------------------------|
| A. AT LEAST 5' FROM ANY OVERHANG | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| B. AT LEAST 50' FROM ANY SEPTIC TANK | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| C. AT LEAST 10' FROM TOWN SEWER LINE | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TIE FIELD | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 120' FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

Handwritten signature and date: NOV 10 1985

Handwritten: Q;21-17

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top soil	0	6"
very fine to coarse sand	6"	5'
very fine to fine sand		
tan sand	5	25
gray clay & wood	25	53
very fine to med coarse gray sand		
within layers of		
gray clay	53	69
very fine to coarse		
gray sand	69	86

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME White Drilling Corp
 SIGNATURE OF DRILLER IN CHARGE B. Allen White Sr. DATE 8/13/85