

WOM

Q:31-07

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
59 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL


WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

PAGE 1 OF 1 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 165060-W	LOCAL ID#	
PROPERTY OWNER Town Of Bethany Beach / Parcel #6		
WELL CONTRACTOR American Water Well Systems, Inc.	LIC# 608	
DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0'	1'
Orange Clay	1'	5'
Tan clay with medium sand	5'	25'
Gray clay	25'	40'
Gray medium / coarse sand	40'	100'
Tan medium / coarse sand	100'	140'
Medium / coarse gray sand	140'	270'
Medium/coarse gray sand with gray clay	270'	280'
Medium dark brown sand	280'	320'
Medium light brown sand	320'	350'
Medium gray sand	350'	395'
Medium gray sand with shell	395'	410'
OTHER COMMENTS:		



I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Alan Perazich
Signature of Well Driller In Charge

608
License#

7/1/99
Date