

# Water Well Contractors

CUSTOMER SEA COLONY, INC. JOB 4854  
 ADDRESS South Bethany Beach, Del. DATE 3/19/79  
 LOCATION 750' North of Well #1

		FEET FROM GROUND SURFACE 0 TO.....	QJ 41-03 WELL LOG
331 (CASING)	0 - 1	top soil	
	1 - 19	fine to med tan sand	
	19 - 61	fine to med gray sand w/5% clay	
	61 - 191	fine to coarse gray sand	
	191 - 245	fine to coarse gray sand w/10% clay	
	245 - 281	blue clay	
	281 - 370	fine to coarse gray sand	
	370 - 420	fine to med sand w/20% clay	
TOTAL DEPTH 331 (SCREEN)			

WELL NO. <u>331</u>	WELL NO. <u>366</u>
DES. PLANNED <u>10</u>	DES. PLANNED <u>10</u>
CAPACITY G.P.M. <u>60</u>	DRILLING MACHINE NO. <u>D3</u>
STATIC LEVEL <u>GROUND LEVEL</u>	DRILLER <u>B. KELLEY/C. WALLACE</u>
PAVING LEVEL <u>4'</u>	GRAVEL <u>2 &amp; 3</u>
SPECIFIC CAPACITY <u>15</u>	BAGS OF CEMENT <u>30</u>
PAVED WITH <u>BIT &amp; CONCRETE</u>	DATE WELL COMPLETED <u>3/23/79</u>
DEPTH OF CEMENT GROUT <u>0 - 250</u>	DRILLER'S HELPER <u>G. Phillips</u>
	<u>Ed. Kelley</u>