

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WD-2
 7/69

WELL COMPLETION REPORT

QJ52-14

1. Permit Number: 31272
 Owner of Well: Atlet Cages

2. Test Well:
 Observation Well:
 Production Well:
 Well Abandoned? Yes No

3. Total Well Depth: 130 feet
 Date Completed: 6-29-76

4. Grout Type: Cement
 from 3 feet to 15 feet
 from _____ feet to _____ feet

5. Casing Type: PVC
0 inches to 120 feet
0 inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
120 feet to 130 feet

7. Gravel Packed? Yes No
115 feet to 130 feet

8. Well Head Completion:
No Pitless Adapter _____ Type _____
 _____ inches above grade

9. Static Water Level:
9 feet below grade
 _____ feet above grade

10. Pumping Water Level:
15 feet below grade after
1 hour at 15 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
White sand-med	0	8
Gravel med	8	12
White sand-med	12	24
tan sand-fine to med	24	36
gray clay & sand	36	55
tan gray sand-med	55	90
light tan sand-med	90	105
tan gray sand-med	105	130

14. Signature of Water Well Contractor: Steve Will Hallen Date: 7-1-76

2
 E
 MIT
 RILLING
 Year
 2
 NY
 Permit No. 31272
 on the
 drawing