

67773 LOCAL ID

Whitaker Lakeland

DATE 12-19-86

TEST PERMANENT

DOMESTIC AGRICULTURAL
COMMERCIAL INDUSTRIAL
IRRIGATION PUBLIC
MONITOR DEWATERING
HEAT PUMP RECHARGE HEAT PUMP SUPPLY

OTHER (Specify)
REPLACEMENT WELL? YES NO

INSTALLMENT DATE FOR OLD WELL
INSTALLMENT METHOD

DRILLING METHOD
BORED CABLE TOOL
JETTED AIR ROTARY
REVERSE WASHED

DEPTH DRILLED

CASING SEQUENCE

Table with 2 columns: INNER, OUTER. Rows: 2', 145', 2" PVC

SCREEN SEQUENCE

Table with 2 columns: INNER, OUTER. Rows: 145', 125', 2" O.D. PVC

WRITTEN APPROVAL FOR SCREENS/GRAVEL PACKING MORE THAN ONE FOOTER MUST BE OBTAINED FROM DRILLER.

PIPE: CEMENT BENTONITE CLAY

40 TO 0 FEET

OUTER BACKFILL OF WELL ANNULUS

Material FROM 40 TO 120 FEET

PACK: TYPE H2

125' TO 130' FEET

WATER LEVEL: DATE 12-19-86

(Below, above) GROUND SURFACE

WATER LEVEL: 20 FT. BELOW GRADE

4 HOURS AT 60 GPM.

HEAD COMPLETION:
SS ACAS FOR

INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N/A
RATED CAPACITY (GPM) N/A
PUMP INTAKE SETTING N/A FT. BELOW GRADE

THE COMPLETED WELL IS?

A. AT LEAST 5' FROM ANY OVERHANG
B. AT LEAST 50' FROM ANY SEPTIC TANK
C. AT LEAST 10' FROM TOWN SEWER LINE
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED

MAR 13 1987

WATER SUPPLY

205 TAX

(E)

4/11/00

QJ 52-36

DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

Table with 3 columns: DESCRIPTION, TOP OF STRATA, BOTTOM OF STRATA. Rows: Top Soil, Fine to med sand, Heavy clay, Fine to med sand, Heavy clay, Fine to med sand, Heavy clay, Fine to med sand, Heavy clay, Fine to med sand, Fine to med sand.

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME D. H. H. S.

SIGNATURE OF DRILLER IN CHARGE: Edward Kelley/jr DATE 12-23-86