

67774 LOCAL ID
 (John Fitzgerald) 67774

TYPE OF PERMANENT PUMP INSTALLED:
 PUMP MANUFACTURE NA
 RATED CAPACITY (GPM)
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

INSTALLATION DATE 12/17/86
 TEST PERMANENT

THE COMPLETED WELL IS?
 YES NO
 A. AT LEAST 5' FROM ANY OVERHANG
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS _____ FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

REPLACEMENT WELL? YES NO
 INSTALLMENT DATE FOR OLD WELL _____
 INSTALLMENT METHOD _____

DRILLING METHOD
 BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED

TYPE OF DRILL _____
 DEPTH DRILLED _____

CASING SEQUENCE

DEPTH	DIAMETER	MATERIAL
2'	2"	PVC
145'	2"	PVC

SCREEN SEQUENCE

DEPTH	DIAMETER	MATERIAL
145'	2"	PVC
155'	2"	PVC

TOP OF SCREEN _____
 BOTTOM OF SCREEN _____
 DIAMETER _____
 MATERIAL _____

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE FOOT FROM SEPTIC OR CESSPOOL _____

TYPE OF CEMENT BENTONITE CLAY

OUTER BACKFILL OF WELL ANNULUS
 FROM 120' TO 40' FEET
 PACK TYPE #2

WATER LEVEL: DATE 12-17-86
 (Below, above) GROUND SURFACE
 WATER LEVEL: 18 FT. BELOW GRADE
 2 HOURS AT 60' GPM.

HEAD COMPLETION:
 SS ADAPTOR
 _____ INCHES ABOVE GRADE.

TAX 4/4/00
 205
 DEC 31 1986
 WATER SUPPLY
 QJ52-37

DRIERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Soil to Med Sand	1	33
Clay	33	48
Soil to Med Sand with Clay	48	80
Soil to coarse Sand & Gravel	80	103
Heavy Clay	103	123
Soil to coarse Sand & Gravel	123	158
Heavy Clay	158	165

SUPPLEMENTAL DRIERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME C. W. Co. A.
 SIGNATURE OF DRILLER IN CHARGE Eddy Taylor DATE 12-17-86