

LOCAL ID

TYPE OF PERMANENT PUMP INSTALLED:

B. Baughner

PUMP MANUFACTURE _____
RATED CAPACITY (GPM) _____
PUMP INTAKE SETTING _____ FT. BELOW GRADE

DATE 8-14-80
TEST PERMANENT

THE COMPLETED WELL IS?

STIC AGRICULTURAL
IERCIAL INDUSTRIAL
ATION PUBLIC
OR DEWATERING
PUMP RECHARGE HEAT PUMP SUPPLY

A. AT LEAST 5' FROM ANY OVERHANG YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

MENT WELL? YES NO
DATE FOR OLD WELL _____
METHOD _____

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 100 FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO
IF NO. DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

DRILLING METHOD

BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED

TAK 4/11/00

RECEIVED

WATER SUPPLY
205 QJ52-39

CASING SEQUENCE

DEPTH	DIAMETER
+2	-19
-19	-124
2	2
STL	PVC

SCREEN SEQUENCE

DEPTH	DIAMETER
-150	
-170	
2	
PVC	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE ANNU- WELLS MUST BE OBTAINED FROM DAREC.

EMENT BENTONITE CLAY

TO -21 FEET
CKFILL OF WELL ANNULUS
FROM -21 TO -140 FEET

TO 170 FEET
LEVEL: DATE 8/14/80
(above) GROUND SURFACE
LEVEL: 17 FT. BELOW GRADE
HOURS AT 40 GPM.

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
F-M GRAY SAND	1	13
F-C GRAY SAND	13	24
BLUE CLAY	24	43
F-M GRAY SAND	43	78
F-C GRAY SAND	78	93
GRAY CLAY	93	109
F-SAND w/CLAY LAMIN	109	135
F-C GRAY SAND	135	170
GRAY CLAY	176	180

COMPLETION:
ADAPTOR
GRADE

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF _____ PAGES
COMPANY NAME AWWIS
SIGNATURE OF DRILLER IN CHARGE [Signature] DATE 10/1/80