

Permit Number: 59#3  
Owner of Well: Charles W. Bell

Test Well \_\_\_\_\_  
Observation Well \_\_\_\_\_  
Production Well   
Well Abandoned? Yes \_\_\_\_\_ No \_\_\_\_\_

Total Well Depth 53 feet  
Date Completed 9-19-77

Grout: Type Cement  
from 0 feet to 15 feet  
from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Casing: Type PVC  
0 inches to 48 feet  
\_\_\_\_\_ inches to \_\_\_\_\_ feet  
Drive Shoe? Yes \_\_\_\_\_ No

Screen Setting:  
48 feet to 53 feet

Gravel Packed? Yes  No \_\_\_\_\_  
46 feet to 53 feet

8. Well Head Completion:  
no Pitless Adapter \_\_\_\_\_ Type \_\_\_\_\_  
\_\_\_\_\_ inches above grade

9. Static Water Level:  
7 feet below grade  
\_\_\_\_\_ feet above grade

10. Pumping Water Level:  
12 feet below grade after  
1 hour at 55 GPM

11. Permanent Pump Installed?  
Yes \_\_\_\_\_ No   
a. Shallow Well \_\_\_\_\_  
Deep Well \_\_\_\_\_  
b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
Centrifugal \_\_\_\_\_ Jet \_\_\_\_\_  
Submersible \_\_\_\_\_  
c. Capacity \_\_\_\_\_ GPM

12. Well Number \_\_\_\_\_  
(Leave Blank)

WATER SUPPLY BRANCH  
OCT 13 1977

Rc22-06

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil		
brn med-fine		
brn clay		
lt tan med-fine		
lt tan med-med		
brn med-med coarse		

Signature of Water Well Contractor  
Charles W. Bell

Date  
10/11/77