

WATER AND AIR RESOURCES COMMISSION

Water Resources Division

Dover, Delaware 19901

WELL COMPLETION REPORT



1. Permit Number: 39183
 Owner of Well: Charles W. Bell

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 53 feet
 Date Completed 9-19-77

4. Grout: Type Cement
 from 0 feet to 15 feet
 from _____ feet to _____ feet

5. Casing: Type PVC
0 inches to 48 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
48 feet to 53 feet

7. Gravel Packed? Yes No
46 feet to 53 feet

8. Well Head Completion:
1 1/2 Pitless Adapter
 _____ inches above grade

9. Static Water Level:
7 feet below grade
 _____ feet above grade

10. Pumping Water Level:
12 feet below grade after
1 hour at 30 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

WATER SUPPLY BR
 OCT 13 1977

RC22-14

| Formation | Thickness of Stratum | Depth to Bottom Stratum |
|-----------------------|----------------------|-------------------------|
| Top soil | | |
| 1m med. fine | | |
| 1m clay | | |
| 1.5m med. fine | | |
| 1.5m med. med. coarse | | |
| | | |
| | | |