

Name of Well: 71422  
 Owner of Well: Alvin Brown  
 Observation Well   
 Production Well   
 Well Abandoned? Yes  No   
 Total Well Depth 58 feet  
 Date Completed 7-14-76  
 Grout: Type Cement  
 from 3 feet to 15 feet  
 from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Casing: Type PVC  
0 inches to 53 feet  
 inches to \_\_\_\_\_ feet  
 Drive Shoe? Yes  No   
 Screen Setting:  
53 feet to 58 feet  
 Gravel Packed? Yes  No   
51 feet to 58 feet

6. Well Head Completion:  
10 Pitless Adapter \_\_\_\_\_ Type \_\_\_\_\_  
 \_\_\_\_\_ inches above grade  
 9. Static Water Level:  
9 feet below grade  
 \_\_\_\_\_ feet above grade  
 10. Pumping Water Level:  
20 feet below grade after  
1 hour at 25 GPM  
 11. Permanent Pump Installed? Yes  No   
 a. Shallow Well \_\_\_\_\_  
 Deep Well \_\_\_\_\_  
 b. Reciprocating \_\_\_\_\_ Rotary \_\_\_\_\_  
 Centrifugal \_\_\_\_\_ Jet \_\_\_\_\_  
 Submersible \_\_\_\_\_  
 c. Capacity \_\_\_\_\_ GPM  
 12. Well Number \_\_\_\_\_  
 (Leave blank)

b. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
Brown sand - Med.	1	8
Brown clay	8	12
to Top sand - Med.	12	18
White sand - Med.	18	30
to Brown sand - Med.	30	38
Brown clay	38	41
to Brown sand - Med.	41	50
Brown sand - Med.	50	58

4. Signature of Water Well Contractor Alvin Brown Date 7-15-76