

1. Owner of Well: Richard S. Hunter

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 58 feet
 Date Completed 8-12-75

4. Grout: type Cement
 from 3 feet to 15 feet
 from _____ feet to _____ feet

5. Casing: Type PVC
3 inches to 53 feet
 _____ inches to _____ feet
 Drive Shaft? Yes No

6. Screen Setting:
53 feet to 58 feet

7. Gravel Packed? Yes No
50 feet to 58 feet

8. Well Head (to 20 ft):
20 ft. Item Chapter _____ Type _____
2 inches above grade

9. Static Water Level:
5 feet below grade
 _____ feet above grade

10. Pumping Water Level:
35 feet below grade after
1 hours at 25 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil	1	1
1/2 in sand - med	1	15
1/2 in clay	15	18
1/2 in sand - med	12	22
gray clay	25	30
1/2 in clay	30	41
1/2 in sand - med	41	49
1/2 in sand - coarse	29	58

14. Signature of Water Well Contractor Richard S. Hunter Date 10-18-75